

## Inspections List

### APPLICATION NO F/97/02137

**Proposal:** Single storey rear extension  
**Address:** 3 Alexandra Grove London N12

Inspection Type	Inspection date	Officer
Plot Notes: F97/2137 10/12/97 Bases out at 2.4m depth on firm brown chalky clay below level of drain found: excavations to be deeper. NL 11/12/97 Excavations now approximately 1.2-2.4m deep on firm brown chalky clay. All excavations now completed. NL 18/12/97 9 inch DPC bedded and lapped with existing. Builder to cut and lap strip of 1200g DPM with DPC before continuing. MF 08/01/98 Shell constructed, all appears as per details. NL 12/01/98 Drain to new RWP's laid. NL 22/5/02 - Work complete but garage made into 2 rooms and a hallway. Regularisation application for conversion of garage to extend existing flat required. Agreed will be ok if door provided to new hall into garden. NL 10/06/02 - Above items now done therefore works now complete. NL		
Inspection Notes:		